



- NOTES:
1. PROGRAMMING: DRIVE MACRO = E-CLIPSE. BYPASS MACRO = HVAC DEFAULT.
  2. DASH LINES INDICATE CUSTOMER INSTALLED DEVICES AND WIRING
  3. COPPER WIRE RATED FOR 60°C INSULATION IF RATED LESS THAN 100A OR 75°C IF RATED 100A OR MORE MUST BE USED.
  4. REFER TO USER MANUAL FOR OPERATION, CONNECTIONS AND TIGHTENING TORQUE VALUES.
  5. FUSE RATING LABEL IS NEAR DEVICE.
  6. CUSTOMER REQUIRED TO PROVIDE BRANCH CIRCUIT PROTECTION AND DISCONNECT MEANS PER NEC AND LOCAL CODE.
  7. SHORT CIRCUIT CURRENT: SKA RMS SYMMETRICAL 600V MAXIMUM.

Rev	SEE ECN 10003203	06/23/09	DC	Description	ACX550	Project Name	AHX550 E-CLIPSE BYPASS INPUT DISCONNECT SWITCH	Approved By	J. Truettner	Checked By	J. Brenner	Responsible	ABBB	Date	9/19/2007	Reference Number	BD00R656PW-A	Sheet	A
Based On					Power Wiring Diagram			Prepared By	Sch Gen				ABB Inc.					Cont.	B