



- NOTES:
1. PROGRAMMING: DRIVE MACRO = E-CLIPSE, BYPASS MACRO = HVAC, DEFAULT.
 2. DASH LINES INDICATE CUSTOMER INSTALLED DEVICES AND WIRING
 3. COPPER WIRE RATED FOR 60°C INSULATION IF RATED LESS THAN 100A OR 75°C IF RATED 100A OR MORE MUST BE USED.
 4. REFER TO USER MANUAL FOR OPERATION, CONNECTIONS AND TIGHTENING TORQUE VALUES.
 5. FUSE RATING LABEL IS NEAR DEVICE.
 6. CUSTOMER REQUIRED TO PROVIDE BRANCH CIRCUIT PROTECTION AND DISCONNECT MEANS PER NEC AND LOCAL CODE.
 7. SHORT CIRCUIT CURRENT: 100KA RMS SYMMETRICAL, 480V MAXIMUM WITH REQUIRED FUSES. REFER TO RATING LABEL OR SUBMITTAL SCHEDULE FOR TYPE AND SIZE.

Rev	SEE ECN 10003203	06/23/09	DC	Description	Project Name	Approved By	Responsible	Date	Reference Number	Sheet
Based On	Description	Date	Appd	Power Wiring Diagram	ACH550 E-CLIPSE BYPASS INPUT DISCONNECT SWITCH	Checked J. Truettner Prepared J. Brenner	Resp. def. J. J.	9/19/2007	BD00R046PW-A Document Number 3AUAD0000014954	A B