



- NOTES:
1. PROGRAMMING: DRIVE MACRO = HVAC DEFAULT.
 2. DASH LINES INDICATE CUSTOMER INSTALLED DEVICES AND WIRING
 3. COPPER WIRE RATED FOR 60°C INSULATION IF RATED LESS THAN 100A OR 75°C IF RATED 100A OR MORE MUST BE USED.
 4. REFER TO USER MANUAL FOR OPERATION, CONNECTIONS AND TIGHTENING TORQUE VALUES.
 5. FUSE RATING LABEL IS NEAR DEVICE.
 6. CUSTOMER REQUIRED TO PROVIDE BRANCH CIRCUIT PROTECTION AND DISCONNECT MEANS PER NEC AND LOCAL CODE.
 7. SHDRT CIRCUIT CURRENT: SKA RMS SYMMETRICAL 600V MAXIMUM.

| | | | | | | | | | | | |
|----------|------------------|----------|------|-------------|--|-----------------------|-------------------|----------|-----------|------------------------------------|------------|
| Rev | SEE ECN 10003203 | 06/23/09 | DC | ACX550 | ACX550 PACKAGED DRIVE INPUT SWITCH AND FUSES | J. Truettner | ABB | ABB Inc. | 9/19/2007 | PD00R656PW-A | Sheet A |
| Based On | Description | Date | Appd | Description | Project Name | Checked J. Brenner | Responsible AJ | | | Document Number 3AU/A0000014954 | Cont. B |

1
3
5
7
9
11
13
15
17
19
21
23
25
27
29
31
33
35
37
39
41
43
45
47

1
3
5
7
9
11
13
15
17
19
21
23
25
27
29
31
33
35
37
39
41
43
45
47