



- NOTES:
1. APPLICATION MACRO: 'E-CLIPSE BYPASS' DEFAULT.
 2. CONSULT USER'S MANUAL FOR I/O RATINGS.
 3. REPLACE JUMPER WITH NORMALLY CLOSED SAFETY INTERLOCK CONTACT AS NEEDED.
 4. COPPER WIRE RATED FOR 60°C INSULATION IF RATED LESS THAN 100A OR 75°C IF RATED 100A OR MORE MUST BE USED.
 5. REFER TO USER MANUAL FOR OPERATION, CONNECTIONS AND TIGHTENING TORQUE VALUES.
 6. CUSTOMER REQUIRED TO PROVIDE BRANCH CIRCUIT PROTECTION AND DISCONNECT MEANS PER NEC AND LOCAL CODE.

Rev	Description	Date	App'd	Project Name	Approved By	Responsible	Date	Reference Number	Sheet
L	SEE ECN 10003203	06/23/09	JDC	ACH550 Control Wiring Diagram	J. Truettner	ABB	9/19/2007	VCVDR014CC-A	1 of 2
Rev	Description	Date	App'd	Project Name	Approved By	Responsible	Date	Reference Number	Sheet
				ACH550 E-CLIPSE I/O	J. Truettner	ABB		3AUAD0000014954	