



---

**Supplement for the HE693PIF400 User Manual  
(MAN0069-01)**

**Purpose:** The purpose of this supplement is to describe the procedure to insure that the IC693PIF400/HE693PIF400 meets CE Mark compliance.

**Cables:** Supply a cable to connect the PIF400 card to the I/O racks. The cable features need to include seven twisted pairs with a 360 degree termination on the shielding. This must be done to achieve CE Mark compliance. Any unused conductors must be soldered to ground.

**RUN - Relay circuit:**

In order to achieve CE Mark compliance, the relay can only be used for switching DC voltage. The DC cable requires a ferrite bead with six passes through the ferrite.

**NOTE:** If these procedures are not followed, high frequency noise emissions may result.