

AutomationDirect Productivity 3000 Ethernet Driver Help

© 2011 Kepware Technologies

Table of Contents

Table of Contents	2
AutomationDirect Productivity 3000 Ethernet Driver Help	4
Overview	4
Device Setup	5
Communication	5
Data Handling	6
Tag Import File Path	6
Automatic Tag Database Generation	8
Optimizing Your AutomationDirect Productivity 3000 Ethernet Communications	10
Data Types Description	11
Address Descriptions	12
Ordering of Array Data	13
Address Formats	13
Error Descriptions	15
Modbus Exception Codes	15
Automatic Tag Database Generation Error Messages	16
Tag name <tag name> encountered validation error and will not be imported	16
Unable to generate a tag database for device <device name>. Reason: Auto tag generation aborted.	16
Unable to generate a tag database for device <device name>. Reason: Import file is invalid or corrupt. ...	16
Unable to generate a tag database for device <device name>. Reason: Import file not found.	16
Unable to generate a tag database for device <device name>. Reason: Low memory resources.	17
Driver Error Messages	17
Unable to bind to adapter: <network adapter>. Connect failed. Winsock Err# <error number>	17
Winsock initialization failed (OS Error = <OS error code>)	17
Winsock shut down failed (OS Error = <OS error code>)	17
Winsock V1.1 or higher must be installed to use the Productivity 3000 Ethernet device driver.	18
Read Errors	18
Cannot read <tag count> items starting at tag '<tag address>': System ID '<System ID>' does not exist ..	18
in device '<device name>'	18
Cannot read tag '<tag address>': System ID '<System ID>' does not exist in device '<device name>'	18
Cannot read <tag count> items starting at tag '<tag address>': address does not exist in device	19
'<device name>'	19
Cannot read tag '<tag address>': address does not exist in device '<device name>'	19
Cannot read <tag count> items starting at tag '<tag address>': value is invalid for data type '<data	19
type>' in device '<device name>'	19
Cannot read tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>' ..	19
.....	19
Cannot read <tag count> items starting at tag '<tag address>': error receiving response frame from	19
device '<device name>'	19
Cannot read tag '<tag address>': error receiving response frame from device '<device name>'	20

Cannot read <tag count> items starting at tag '<tag address>': device '<device name>' returned error ...
code <error code>..... 20

Cannot read tag '<tag address>': device '<device name>' returned with error code <error code>..... 20

Write Errors..... 20

Cannot write to tag '<tag address>': System ID '<System ID>' does not exist in device '<device name>'.. 20

Cannot write to tag '<tag address>': address does not exist in device '<device name>'..... 21

Cannot write to tag '<tag address>': value is invalid for data type '<data type>' in device '<device
name>'..... 21

Cannot write to tag '<tag address>': error receiving response frame from device '<device name>'..... 21

Cannot write to tag '<tag address>': device '<device name>' returned with error code <error code>..... 21

Index..... 22

AutomationDirect Productivity 3000 Ethernet Driver Help

Help version 1.032

CONTENTS

[Overview](#)

What is the AutomationDirect Productivity 3000 Ethernet Driver?

[Device Setup](#)

How do I configure a device for use with this driver?

[Automatic Tag Database Generation](#)

How can I easily configure tags for the AutomationDirect Productivity 3000 Ethernet driver?

[Optimizing Your AutomationDirect Productivity 3000 Ethernet Communications](#)

How do I get the best performance from the AutomationDirect Productivity 3000 Ethernet driver?

[Data Types Descriptions](#)

What data types does the AutomationDirect Productivity 3000 Ethernet driver support?

[Address Descriptions](#)

How do I reference a data location in a Productivity 3000 Ethernet device?

[Error Descriptions](#)

What error messages does the AutomationDirect Productivity 3000 Ethernet driver produce?

Overview

The AutomationDirect Productivity 3000 Ethernet Driver provides an easy and reliable way to connect AutomationDirect Productivity 3000 Ethernet devices to OPC Client applications, including HMI, SCADA, Historian, MES, ERP and countless custom applications.

Device Setup

Supported Devices

P3-550

Important: This device cannot be used as a MODBUS TCP server if DHCP IP addressing is being used.

Firmware Versions

P3-550: ver.1.0.7.2

Hardware Setup

It is strongly recommended that the device be configured with "No exception response for non-existing Modbus address requests" checked. This is the default setting. For more information, refer to the device's programming software under "Project Properties: Modbus Server Settings."

Maximum Number of Channels and Devices

Maximum number of channels and devices supported by this driver are as follows:

100 channels

256 devices

Device ID

This parameter specifies the IP address of the device with the extension `:#` where `#` is the Slave ID.


Cable Diagrams

Patch Cable (Straight Through)

TD + 1	OR/WHT	OR/WHT	1 TD +
TD - 2	OR	OR	2 TD -
RD + 3	GRN/WHT	GRN/WHT	3 RD +
4	BLU	BLU	4
5	BLU/WHT	BLU/WHT	5
RD - 6	GRN	GRN	6 RD -
7	BRN/WHT	BRN/WHT	7
8	BRN	BRN	8

RJ45 RJ45

10 BaseT



Crossover Cable

TD + 1	OR/WHT	GRN/WHT	1 TD +
TD - 2	OR	GRN	2 TD -
RD + 3	GRN/WHT	OR/WHT	3 RD +
4	BLU	BLU	4
5	BLU/WHT	BLU/WHT	5
RD - 6	GRN	OR	6 RD -
7	BRN/WHT	BRN/WHT	7
8	BRN	BRN	8


RJ45 RJ45

8-pin RJ45

Communication

Port

This parameter is used to specify the port number. The default setting is 502.




Note: The default communication protocol is Modbus TCP/IP.

Data Handling

First Word Low

When First Word Low is checked, the driver will assume that the first register used to construct a 32 bit value is the low word. When this setting is unchecked, the driver will assume that the first register is the high word.



Tag Import File Path

Tag Import File

Enter the exact location of the tag import file (*filename.csv*). The CSV file needs to be created in the Productivity Suite Programming Software. The tag import file will be used by the Automatic Tag Database Generation feature to create the tag database. All tags will be imported and expanded according to their respective data types.



See Also: [Automatic Tag Database Generation](#)

Automatic Tag Database Generation


The AutomationDirect Productivity 3000 Ethernet driver makes use of the OPC server's Automatic Tag Database Generation feature. This enables the driver to automatically create tags that access data points used in a device configuration.

The OPC server will use the tag import file to create the tag database. For more information, refer to [Tag Import File Path](#).


Note: The tag import file (*.csv) needs to be created in the Productivity Suite Programming Software.

To run the tag database generation for a device, perform the following steps.

1. In the OPC server project, right-click on the device. Select **Properties**.



2. Click on the **Tag Settings** tab.



3. Use **Browse** to locate the folder containing the import file (*.csv). Then, select the import file.
4. Click **OK** to start the import and tag generation process.


5. The OPC Server's event log will show when the tag generation process started, in addition to any errors that occurred while processing and when the process completed.

Note: For more information, refer to the section on Automatic OPC Tag Database Generation in the OPC Server's help file.

Optimizing Your AutomationDirect Productivity 3000 Ethernet Communications


The AutomationDirect Productivity 3000 Ethernet driver has been designed to provide the best performance with the least amount of impact on the system's overall performance. While the AutomationDirect Productivity 3000 Ethernet driver is fast, there are a couple of guidelines that can be used in order to control and optimize the application and gain maximum performance.

Our server refers to communications protocols like AutomationDirect Productivity 3000 Ethernet driver as a channel. Each channel defined in the application represents a separate path of execution in the server. Once a channel has been defined, a series of devices must then be defined under that channel. Each of these devices represents a single controller from which data will be collected. While this approach to defining the application will provide a high level of performance, it won't take full advantage of the AutomationDirect Productivity 3000 Ethernet driver or the network. An example of how the application may appear when configured using a single channel is shown below.



Each device appears under a single AutomationDirect Productivity 3000 Ethernet driver channel. In this configuration, the driver must move from one device to the next as quickly as possible in order to gather information at an effective rate. As more devices are added or more information is requested from a single device, the overall update rate begins to suffer.

If the AutomationDirect Productivity 3000 Ethernet driver could only define one single channel, then the example shown above would be the only option available; however, the AutomationDirect Productivity 3000 Ethernet driver can define up to 256 devices per 100 channel. Using multiple channels distributes the data collection workload by simultaneously issuing multiple requests to the network. An example of how the same application may appear when configured using multiple channels to improve performance is shown below.



Each device has now been defined under its own channel. In this new configuration, a single path of execution is dedicated to the task of gathering data from each device. If the application has 256 or fewer devices, it can be optimized exactly how it is shown here.

The performance will improve even if the application has more than 256 devices. While 256 or fewer devices may be ideal, the application will still benefit from additional channels. Although spreading the device load across all channels will cause the server to move from device to device again, it can now do so with far less devices to process on a single channel.

See Also: [Data Handling](#)

Data Types Description

Data Type	Description
Boolean	Single bit.
Byte	Unsigned 8 bit value. bit 0 is the low bit. bit 7 is the high bit.
Word	Unsigned 16 bit value. bit 0 is the low bit. bit 15 is the high bit.
Short	Signed 16 bit value. bit 0 is the low bit. bit 14 is the high bit. bit 15 is the sign bit.
DWord	Unsigned 32 bit value. bit 0 is the low bit. bit 31 is the high bit.
Long	Signed 32 bit value. bit 0 is the low bit. bit 30 is the high bit. bit 31 is the sign bit.
BCD	Two byte packed BCD. Value range is 0-9999. Behavior is undefined for values beyond this range.
LBCD	Four byte packed BCD. Value range is 0-99999999. Behavior is undefined for values beyond this range.
Float	32 bit floating point value. The driver interprets two consecutive registers as a floating point value by making the second register the high word and the first register the low word.
String	Null terminated ASCII string. Support includes HiLo LoHi byte order selection.

Address Descriptions

The default data types are shown in **bold**.

System Index Addresses

Device Type	Range	Data Type	Access
Analog Input Float 32	AIF32-00.00.00.01-AIF32-99.05.11.32	Float	Read Only
Analog Input Signed 32	AIS32-00.00.00.01-AIS32-99.05.11.32	Long	Read Only
Analog Output Float 32	AOF32-00.00.00.01-AOF32-99.05.11.32	Float	Read/Write
Analog Output Signed 32	AOS32-00.00.00.01-AOS32-99.05.11.32	Long	Read/Write
Discrete Inputs	DI-00.00.00.01-DI-99.05.11.128	Boolean	Read Only
Discrete Outputs	DO-00.00.00.01-DO-99.05.11.128	Boolean	Read/Write
I/O Module Status Bits	MST-00.00.00.01-MST-99.05.11.128	Boolean	Read Only

Continuous Addresses

Device Type	Range	Data Type	Access
Internal BCD 16	BCD16-000001-BCD16-999999	BCD	Read/Write
Internal BCD 32	BCD32-000001-BCD32-999999	LBCD	Read/Write
Internal Bits	C-000001-C-999999	Boolean	Read/Write
Internal Float 32	F32-000001-F32-999999	Float	Read/Write
Internal Unsigned 8	US8-000001-US8-999999	Byte	Read/Write
Internal Signed 16	S16-000001-S16-999999	Short	Read/Write
Internal Signed 32	S32-000001-S32-999999	Long	Read/Write
String	STR-000001:1-STR-999999:128	String	Read/Write
System String	SSTR-000001:1-SSTR-999999:50	String	Read Only
System Read Only Bit	SBR-000001-SBR-999999	Boolean	Read Only
System Read/Write Bit	SBRW-000001-SBRW-999999	Boolean	Read/Write
System Read Only Word	SWR-000001-SWR-999999	Word	Read Only
System Read/Write Word	SWRW-000001-SWRW-999999	Word	Read/Write
Internal Unsigned 16	US16-000001-US16-999999	Word	Read/Write

One Dimensional Array Elements

Device Type	Range	Data Type	Access
1 Dimensional Internal BCD 16	AR1BCD16-00001(1)-AR1BCD16-999999(65535)	BCD	Read/Write
1 Dimensional Internal BCD 32	AR1BCD32-00001(1)-AR1BCD32-999999(65535)	LBCD	Read/Write
1 Dimensional Internal Bits	AR1C-000001(1)-AR1C-999999(65535)	Boolean	Read/Write
1 Dimensional Internal Float 32	AR1F32-00001(1)-AR1F32-999999(65535)	Float	Read/Write
1 Dimensional Internal Unsigned 8	AR1US8-00001(1)-AR1US8-999999(65535)	Byte	Read/Write
1 Dimensional Signed 16	AR1S16-00001(1)-AR1S16-999999(65535)	Short	Read/Write
1 Dimensional Signed 32	AR1S32-00001(1)-AR1S32-999999(65535)	Long	Read/Write
1 Dimensional String	AR1STR-00001:1(1)-AR1STR-999999:128(65535)	String	Read/Write
1 Dimensional Internal Unsigned 16	AR1US16-00001(1)-AR1US16-999999(65535)	Word	Read/Write

Two Dimensional Array Elements

Device Type	Range	Data Type	Access
2 Dimensional Internal BCD 16	AR2BCD16-00001(1),(1)-AR2BCD16-999999(65535),(65535)	BCD	Read/Write
2 Dimensional Internal BCD 32	AR2BCD32-00001(1),(1)-AR2BCD32-999999(65535),(65535)	LBCD	Read/Write
2 Dimensional Internal Bits	AR2C-000001(1),(1)-AR2C-999999(65535),(65535)	Boolean	Read/Write
2 Dimensional Internal Float 32	AR2F32-00001(1),(1)-AR2F32-999999(65535),(65535)	Float	Read/Write
2 Dimensional Unsigned Hex 8	AR2US8-00001(1),(1)-AR2US8-999999	Byte	Read/Write

	(65535),(65535)		
2 Dimensional Signed 16	AR2S16-00001(1),(1)-AR2S16-999999 (65535),(65535)	Short	Read/Write
2 Dimensional Signed 32	AR2S32-00001(1),(1)-AR2S32-999999 (65535),(65535)	Long	Read/Write
2 Dimensional String	AR2STR-00001:1(1),(1)-AR2STR- 999999:128 (65535),(65535)	String	Read/Write
2 Dimensional Internal Unsigned 16	AR2US16-00001(1),(1)-AR2US16-999999 (65535),(65535)	Word	Read/Write

See Also: [Ordering of Array Data](#)

Ordering of Array Data

1. Dimensional Arrays - array [dim1]

1 dimensional array data is passed to and from the controller in ascending order:

```
for (dim1=0; dim1<dim1_max; dim1++)
```

Example: 3 element array

```
array [0]
array [1]
array [2]
```

2. Dimensional Arrays - array [dim1, dim2]

2 dimensional array data is passed to and from the controller in ascending order:

```
for (dim1=0; dim1<dim1_max; dim1++)
for (dim2=0; dim2<dim2_max; dim2++)
```

Example: 3X3 element array

```
array [0, 0]
array [0, 1]
array [0, 2]
array [1, 0]
array [1, 1]
array [1, 2]
array [2, 0]
array [2, 1]
array [2, 2]
```

Address Formats

Tag Names

The default tag names are assigned when hardware is added. Tag names for I/O modules generally follow the AAAAA-B.C.D.E format, which is described in the table below.

Notation	Example	Notes
AAAAA-B.C.D.E AAAAA = Category B = Base Group# C = Base# D = Slot# E = Point or Channel Number	DI-0.1.1.1	Discrete Input P3-550

Category

The category of data may also include the data type. Descriptions of the categories are as follows.

- **Discrete I/O points:**
DI = Discrete Input Point
DO = Discrete Output Point

- **Boolean:** This category includes data items other than I/O points. For example, a blown fuse or out-of-range error bits.
MST = Module Status
- **Analog points:** This category uses five digits. The first two digits designate the type of point and the last three digits describe the data type being used.
AIxxx = Analog Input Point
AOxxx = Analog Output Point
xxF32 = Floating Point 32 bit data type
xxS32 = Signed 32 bit data type

Base Group Number

The base group number is where the module resides. For the P3-550, the base group is group 0.

Base Number

The base number within the group is where the module resides. For the P3-550 or P3-RS, the base is base 1.

Slot Number

The slot number in the base is where the module resides. The slot to the right of the CPU is slot 1.

Point or Channel Number

If the tag name is for an I/O point of a module, this digit will be the channel number. If the tag name is for a status indication, this digit will differentiate between them.

For example, a P3-16TR has one fuse on both commons and a blown fuse indicator bit for each. Their default tag names are MST-x.x.x.1 and MST-x.x.x.2. MST-x.x.x.1 is the blown fuse indicator for the fuse on the common of channels 1 through 8.

Error Descriptions

The following error/warning messages may be generated. Click on the link for a description of the message.

Automatic Tag Database Generation Error Messages

[Tag name <tag name> encountered validation error and will not be imported](#)

[Unable to generate a tag database for device <device name>. Reason: Auto tag generation aborted](#)

[Unable to generate a tag database for device <device name>. Reason: Import file is invalid or corrupt](#)

[Unable to generate a tag database for device <device name>. Reason: Import file not found](#)

[Unable to generate a tag database for device <device name>. Reason: Low memory resources](#)

Driver Error Messages

[Unable to bind to adapter: <network adapter>. Connect failed. Winsock Err # <Error number>](#)

[Winsock initialization failed \(OS Error = <error code>\)](#)

[Winsock shut down failed \(OS Error = <error code>\)](#)

[Winsock V1.1 or higher must be installed to use the Productivity 3000 Ethernet device driver](#)

Read Errors

[Cannot read <tag count> items starting at tag '<tag address>': System ID '<System ID>' does not exist in device '<device name>'](#)

[Cannot read tag '<tag address>': System ID '<System ID>' does not exist in device '<device name>'](#)

[Cannot read <tag count> items starting at tag '<tag address>': address does not exist in device '<device name>'](#)

[Cannot read tag '<tag address>': address does not exist in device '<device name>'](#)

[Cannot read <tag count> items starting at tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'](#)

[Cannot read tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'](#)

[Cannot read <tag count> items starting at tag '<tag address>': error receiving response frame from device '<device name>'](#)

[Cannot read tag '<tag address>': error receiving response frame from device '<device name>'](#)

[Cannot read <tag count> items starting at tag '<tag address>': device '<device name>' returned error code <error code>](#)

[Cannot read tag '<tag address>': device '<device name>' returned with error code <error code>](#)

Write Errors

[Cannot write to tag '<tag address>': System ID '<System ID>' does not exist in device '<device name>'](#)

[Cannot write to tag '<tag address>': address does not exist in device '<device name>'](#)

[Cannot write to tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'](#)

[Cannot write to tag '<tag address>': error receiving response frame from device '<device name>'](#)

[Cannot write to tag '<tag address>': device '<device name>' returned with error code <error code>](#)

See Also:

[Modbus Exception Codes](#)

Modbus Exception Codes

The following data is from Modbus Application Protocol Specifications documentation.

Code Dec/Hex	Name	Description
01/0x01	ILLEGAL FUNCTION	The function code received in the query is not an allowable action for the server (or slave). This may be because the function code is only applicable to newer devices and was not implemented in the unit selected. It could also indicate that the server (or slave) is in the wrong state to process a request of this type. For example, because it is unconfigured and is being asked to return register values.
02/0x02	ILLEGAL DATA ADDRESS	The data address received in the query is not an allowable address for the server (or slave). More specifically, the combination of reference number and transfer length is invalid. For a controller with 100 registers, a request with offset 96 and length 4 would succeed, a request with offset 96 and length 5 will generate exception 02.

03/0x03	ILLEGAL DATA VALUE	A value contained in the query data field is not an allowable value for server (or slave). This indicates a fault in the structure of the remainder of a complex request, such as that the implied length is incorrect. It specifically does not mean that a data item submitted for storage in a register has a value outside the expectation of the application program, since the Modbus protocol is unaware of the significance of any particular value of any particular register.
---------	--------------------	---

Automatic Tag Database Generation Error Messages

The following error/warning messages may be generated. Click on the link for a description of the message.

Automatic Tag Database Generation Error Messages

[Tag name <tag name> encountered validation error and will not be imported](#)

[Unable to generate a tag database for device <device name>. Reason: Auto tag generation aborted](#)

[Unable to generate a tag database for device <device name>. Reason: Import file is invalid or corrupt](#)

[Unable to generate a tag database for device <device name>. Reason: Import file not found](#)

[Unable to generate a tag database for device <device name>. Reason: Low memory resources](#)

Tag name <tag name> encountered validation error and will not be imported

Error Type:

Warning

Possible Cause:

The tag import file contains tag(s) that have invalid character(s). This error message will be returned for each tag that contains an invalid character.

Solution:

Remove the invalid character(s).

Unable to generate a tag database for device <device name>. Reason: Auto tag generation aborted

Error Type:

Warning

Possible Cause:

The Automatic Tag Generation process was aborted.

Solution:

Retry the Automatic Tag Generation process.

See Also: [Automatic Tag Database Generation](#)

Unable to generate a tag database for device <device name>. Reason: Import file is invalid or corrupt

Error Type:

Warning

Possible Cause:

The Tag Import File is a corrupt project file.

Solution:

In the OPC server project, right-click on the device and then select **Properties** from the context menu. Next, click on the **Tag Import File Path** tab. Select a valid, properly formatted **Productivity Suite Programming Software Import File**, or produce a new import file by retrying the tag export process in the application.

Unable to generate a tag database for device <device name>. Reason: Import file not found

Error Type:

Warning

Possible Cause:

The Tag Import File could not be found.

Solution:

In the OPC server project, right-click on the device and then select **Properties** from the context menu. Next, click on the **Tag Import File Path** tab. Select a valid, properly formatted **Productivity Suite Programming Software Import File**, or produce a new import file by retrying the tag export process in the application.

Unable to generate a tag database for device <device name>. Reason: Low memory resources

Error Type:

Warning

Possible Cause:

Memory required for database generation could not be allocated. The process is aborted.

Solution:

Close unused applications and/or increase the amount of virtual memory and try again.

Driver Error Messages

The following error/warning messages may be generated. Click on the link for a description of the message.

Driver Error Messages

[Unable to bind to adapter: <network adapter>. Connect failed. Winsock Err # <Error number>](#)

[Winsock initialization failed \(OS Error = <error code>\)](#)

[Winsock shut down failed \(OS Error = <error code>\)](#)

[Winsock V1.1 or higher must be installed to use the Productivity 3000 Ethernet device driver](#)

Unable to bind to adapter: <network adapter>. Connect failed. Winsock Err# <error number>

Error Type:

Fatal

Possible Cause:

1. The operating system could not find an unused port to use for communication with this device.
2. Network system failure, such as Winsock or network adapter failure.
3. Other applications have claimed all available ports (possible but unlikely).

Solution:

1. Reboot the computer and check the network adapter.
2. Check for applications that could be causing conflicts and shut them down.

Winsock initialization failed (OS Error = <OS error code>)

Error Type:

Fatal

OS Error	Indication	Possible Solution
10091	Indicates that the underlying network subsystem is not ready for network communication.	Wait a few seconds and restart the driver.
10067	Limit on the number of tasks supported by the Windows Sockets implementation has been reached.	Close one or more applications that may be using Winsock and restart the driver.

Winsock shut down failed (OS Error = <OS error code>)

Error Type:

Fatal

OS Error	Possible Solution
10036	The network subsystem is still busy with unfinished processing. Wait a few seconds and restart the driver.
10050	The network subsystem has failed. Refer to the Network Administrator.
10093	The network subsystem was not initialized before the shutdown was attempted. Wait a few seconds and try again.

Winsock V1.1 or higher must be installed to use the Productivity 3000 Ethernet device driver

Error Type:

Fatal

Possible Cause:

The version number of the Winsock DLL found on the system is less than 1.1.

Solution:

Upgrade Winsock to version 1.1 or higher.

Read Errors

The following error/warning messages may be generated. Click on the link for a description of the message.

Read Errors

[Cannot read <tag count> items starting at tag '<tag address>': System ID '<System ID>' does not exist in device '<device name>'](#)

[Cannot read tag '<tag address>': System ID '<System ID>' does not exist in device '<device name>'](#)

[Cannot read <tag count> items starting at tag '<tag address>': address does not exist in device '<device name>'](#)

[Cannot read tag '<tag address>': address does not exist in device '<device name>'](#)

[Cannot read <tag count> items starting at tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'](#)

[Cannot read tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'](#)

[Cannot read <tag count> items starting at tag '<tag address>': error receiving response frame from device '<device name>'](#)

[Cannot read tag '<tag address>': error receiving response frame from device '<device name>'](#)

[Cannot read <tag count> items starting at tag '<tag address>': device '<device name>' returned error code <error code>](#)

[Cannot read tag '<tag address>': device '<device name>' returned with error code <error code>](#)

Cannot read <tag count> items starting at tag '<tag address>': System ID '<System ID>' does not exist in device '<device name>'

Error Type:

Warning

Possible Cause:

The PLC returned an error code of 0x01 (illegal function) for a blocked Read transaction.

Solution:

Replace the current System ID with a valid one (as listed in the device protocol).

Cannot read tag '<tag address>': System ID '<System ID>' does not exist in device '<device name>'

Error Type:

Warning

Possible Cause:

The PLC returned an error code of 0x01 (illegal function) for an unblocked Read transaction.

Solution:

Replace the current System ID with a valid one (as listed in the device protocol).

Cannot read <tag count> items starting at tag '<tag address>': address does not exist in device '<device name>'

Error Type:

Warning

Possible Cause:

The PLC returned an error code of 0x02 (illegal data address) for a blocked Read transaction.

Solution:

Replace the current data address with one within the valid range (as listed in the device protocol).

Cannot read tag '<tag address>': address does not exist in device '<device name>'

Error Type:

Warning

Possible Cause:

The PLC returned an error code of 0x02 (illegal data address) for an unblocked Read transaction.

Solution:

Replace the current data address with one within the valid range (as listed in the device protocol).

Cannot read <tag count> items starting at tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'

Error Type:

Warning

Possible Cause:

The PLC returned an error code of 0x03 (illegal data value) for a blocked Read transaction.

Solution:

Replace the current data with valid values (depending on the data type).

Cannot read tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'

Error Type:

Warning

Possible Cause:

The PLC returned an error code of 0x03 (illegal data value) for an unblocked Read transaction.

Solution:

Replace the current data with valid values (depending on the data type).

Cannot read <tag count> items starting at tag '<tag address>': error receiving response frame from device '<device name>'

Error Type:

Warning

Possible Cause:

The response frame received from the PLC contains an error.

Solution:

Check the connection to the PLC and then resend the data.

Cannot read tag '<tag address>': error receiving response frame from device '<device name>'

Error Type:

Warning

Possible Cause:

The response frame received from the PLC contains an error.

Solution:

Check the connection to the PLC and then resend the data.

Cannot read <tag count> items starting at tag '<tag address>': device '<device name>' returned error code <error code>

Error Type:

Warning

Possible Cause:

The PLC has returned an error code.

Solution:

Refer to the list of error code descriptions located in the PLC's manual.

Cannot read tag '<tag address>': device '<device name>' returned with error code <error code>

Error Type:

Warning

Possible Cause:

The PLC has returned an error code.

Solution:

Refer to the list of error code descriptions located in the PLC's manual.

Write Errors

The following error/warning messages may be generated. Click on the link for a description of the message.

Write Errors

[Cannot write to tag '<tag address>': System ID '<System ID>' does not exist in device '<device name>'](#)

[Cannot write to tag '<tag address>': address does not exist in device '<device name>'](#)

[Cannot write to tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'](#)

[Cannot write to tag '<tag address>': error receiving response frame from device '<device name>'](#)

[Cannot write to tag '<tag address>': device '<device name>' returned with error code <error code>](#)

Cannot write to tag '<tag address>': System ID '<System ID>' does not exist in device '<device name>'

Error Type:

Warning

Possible Cause:

The PLC returned an error code of 0x01 (illegal function) for a Write transaction.

Solution:

Replace the current System ID with a valid one (as listed in the device protocol).

Cannot write to tag '<tag address>': address does not exist in device '<device name>'

Error Type:

Warning

Possible Cause:

The PLC returned an error code of 0x02 (illegal data address) for a Write transaction.

Solution:

Replace the current data address with one within the valid range (as listed in the device protocol).

Cannot write to tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'

Error Type:

Warning

Possible Cause:

The PLC returned an error code of 0x03 (illegal data value) for a Write transaction.

Solution:

Replace the current data with valid values (depending on the data type).

Cannot write to tag '<tag address>': error receiving response frame from device '<device name>'

Error Type:

Warning

Possible Cause:

The response frame received from the PLC contains an error.

Solution:

Check the connection to the PLC and then resend the data.

Cannot write to tag '<tag address>': device '<device name>' returned with error code <error code>

Error Type:

Warning

Possible Cause:

The PLC has returned an error code.

Solution:

Refer to the list of error code descriptions located in the PLC's manual.

Index

A

Address Descriptions	12
Address Formats	13
Automatic Tag Database Generation	8
Automatic Tag Database Generation Error Messages	16

C

Cannot read <tag count> items starting at tag '<tag address>': address does not exist in device '<device name>'	19
Cannot read <tag count> items starting at tag '<tag address>': device '<device name>' returned error code <error code>	20
Cannot read <tag count> items starting at tag '<tag address>': error receiving response frame from device '<device name>'	20
Cannot read <tag count> items starting at tag '<tag address>': error receiving response frame from device '<device name>'	19
Cannot read <tag count> items starting at tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'	19
Cannot read tag '<tag address>': address does not exist in device '<device name>'	19
Cannot read tag '<tag address>': device '<device name>' returned with error code <error code>	20
Cannot read tag '<tag address>': System ID '<system ID>' does not exist in device '<device name>'	18
Cannot read tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'	19
Cannot write to tag '<tag address>': address does not exist in device '<device name>'	21
Cannot write to tag '<tag address>': device '<device name>' returned with error code <error code>	21
Cannot write to tag '<tag address>': error receiving response frame from device '<device name>'	21
Cannot write to tag '<tag address>': system ID '<system ID>' does not exist in device '<device name>'	18
Cannot write to tag '<tag address>': System ID '<system ID>' does not exist in device '<device name>'	20
Cannot write to tag '<tag address>': value is invalid for data type '<data type>' in device '<device name>'	21
Communication	5

D

Data Handling	6
Data Types Description	11
Device Setup	5
Driver Error Messages	17

E	
Error Descriptions.....	15
H	
Help Contents.....	4
M	
Modbus Exception Codes.....	15
O	
Optimizing Your AutomationDirect Productivity 3000 Ethernet Communications.....	10
Ordering of Array Data.....	13
Overview.....	4
R	
Read Errors.....	18
T	
Tag Import File Path.....	6
Tag name <tag name> encountered validation error and will not be imported.....	16
U	
Unable to bind to adapter:<network adapter>. Connect failed. Winsock Err# <error number>.....	17
Unable to generate a tag database for device <device name>. Reason: Auto tag generation aborted.....	16
Unable to generate a tag database for device <device name>. Reason: Import file is invalid or corrupt.....	16
Unable to generate a tag database for device <device name>. Reason: Import file not found.....	16
Unable to generate a tag database for device <device name>. Reason: Low memory resources.....	17
W	
Winsock initialization failed (OS Error = <OS error code>).....	17
Winsock shut down failed (OS Error = <OS error code>).....	17
Winsock V1.1 or higher must be installed to use the Productivity 3000 Ethernet device driver.....	18
Write Errors.....	20