

Software Name: MX-AOPC UA Server

Version No.	Build Date No./ Release Date	Supported OS	Apply to Models	New Features/ Enhancements	Bugs Fixed/Changes	Note
v1.6	Build17051914	Windows_10, Windows_7, Windows_8, Windows_Server_2003, Windows_Server_2008, Windows_Server_2008_R2, Windows_Server_2012, Windows_Server_2012_R2	ioLogik 2500 Series, ioLogik E1200 Series, ioLogik E1500 Series, ioLogik E2200 Series, ioLogik E4200, ioLogik W5340-HSPA Series	<p>New Features:</p> <ol style="list-style-type: none"> 1. Link to .NET Framework's download URL. 2. Added license.moxa.com in the expiration warning message. 3. Added Device Timestamp (UTC+T.Z.) column in Viewer. <p>Enhancements:</p> <p>N/A</p>	<p>Bugs Fixed:</p> <ol style="list-style-type: none"> 1. Fixed unable to recognize network adapters setting as teaming mode. 2. Fixed unable to trigger "Update Configuration to Server" button after modifying the Modbus/TCP Tag property. <p>Changes:</p> <p>N/A</p>	N/A
v1.5	Build16082218	Windows_10, Windows_7, Windows_8, Windows_Server_2003, Windows_Server_2008, Windows_Server_2008_R2, Windows_Server_2012, Windows_Server_2012_R2	ioLogik 2500 Series, ioLogik E1200 Series, ioLogik E1500 Series, ioLogik E2200 Series, ioLogik E4200, ioLogik W5340-HSPA Series	<p>New Features:</p> <p>N/A</p> <p>Enhancements:</p> <p>N/A</p>	<p>Bugs Fixed:</p> <ol style="list-style-type: none"> 1. Fixed all tags of ioLogik E1200 series are updated at the same time when on change mode of all tags is enabled. 2. Fixed wrong time zone issue when the tags of ioLogik E1200 series are created on the server at the first time. <p>Changes:</p> <p>N/A</p>	N/A

Software Name: MX-AOPC UA Server

Version No.	Build Date No./ Release Date	Supported OS	Apply to Models	New Features/ Enhancements	Bugs Fixed/Changes	Note
v1.4	Build16072116	Windows_10, Windows_7, Windows_8, Windows_Server_2003, Windows_Server_2008, Windows_Server_2008_R2, Windows_Server_2012, Windows_Server_2012_R2	ioLogik 2500 Series, ioLogik E1200 Series, ioLogik E1500 Series, ioLogik E2200 Series, ioLogik E4200, ioLogik W5340-HSPA Series	New Features: 1. Support MX-AOPC UA Logger. 2. Removed supporting anonymous type connection with OPC UA client for security improvement. Enhancements: N/A	Bugs Fixed: 1. Fixed signed integer data type tag became unknown data type after executing refresh function on Viewer. 2. Fixed string type internal register tag caused Viewer freeze. 3. Fixed OPC UA client did not show device disconnection status when device did not connect to MX-AOPC UA Server. 4. Fixed monitored items without source timestamp and status code. 5. Fixed wrong sampling Interval caused OPC UA client unable to receive tag update notifications. 6. Fixed OPC UA client cannot connect to MX-AOPC UA Server unless CA is trusted when security policy was set to NONE. 7. Fixed OPC UA client still can read tag value when tag quality is in disconnect status. 8. Fixed unable to click "Close" button of Certificate Management dialog on Windows 7 English version and Windows 8 platform. 9. Fixed wrong RTD tag value for the ioLogik E4200 and M-6200. 10. Fixed wrong time zone offset when Device time zone is set to (GMT+12)Fiji, Kamchat. Changes: N/A	N/A
v1.3	Build15090819	Windows_10, Windows_7, Windows_8, Windows_Server_2003, Windows_Server_2008, Windows_Server_2008_R2, Windows_Server_2012, Windows_Server_2012_R2	ioLogik 2500 Series, ioLogik E1200 Series, ioLogik E1500 Series, ioLogik E2200 Series, ioLogik E4200, ioLogik W5340-HSPA Series	New Features: 1. First release for ioLogik 2500-WL1 series. 2. Add "De-active License" function. Enhancements: N/A	Bugs Fixed: N/A Changes: N/A	N/A