

## Software Name: Firmware for ioLogik E2200 Series (E2240)

Version No.	Build Date No./ Release Date	Supported OS	Apply to Models	New Features/ Enhancements	Bugs Fixed/Changes	Note
v3.12.0	Build16122912	N/A	ioLogik E2240-T, ioLogik E2240	<b>New Features:</b> <ol style="list-style-type: none"> <li>Added checking special character function for preventing from Cross-Site Scripting.</li> <li>Added CSRF protection.</li> <li>Increased password length from 8 to 16.</li> <li>Added alive check for 9500 port to MX-AOPC UA Server.</li> </ol> <b>Enhancements:</b> N/A	<b>Bugs Fixed:</b> N/A  <b>Changes:</b> N/A	1. This firmware version works with the ioAdmin V3.13 or later only.
v3.11	Build16010812	N/A	ioLogik E2240-T, ioLogik E2240	<b>New Features:</b> <ol style="list-style-type: none"> <li>Advanced encryption algorithm on password in configuration file(compatible with ioAdmin v3.18</li> </ol> <b>Enhancements:</b> N/A	<b>Bugs Fixed:</b> <ol style="list-style-type: none"> <li>Fixed unable to control output channel through MXview.</li> <li>Fixed blank Email content issue.</li> </ol> <b>Changes:</b> N/A	1. This firmware version works with the ioAdmin V3.13 or later only.
v3.10	Build13092418	N/A	ioLogik E2240, ioLogik E2240-T	<b>New Features:</b> N/A  <b>Enhancements:</b> N/A	<b>Bugs Fixed:</b> <ol style="list-style-type: none"> <li>Web page may not load/open when connecting to AOPC.</li> <li>CGI command causing overflow issue while sending commands to Web Server.</li> <li>Inconsistent idle time out initial value between the Remote Action Server and the other server. They are the same now.</li> <li>Continue writing flash while using DNS.</li> <li>After updating the device's firmware though web page, the device will need to be cold-restarted to complete the process.</li> </ol> <b>Changes:</b> N/A	1. This firmware version works with the ioAdmin V3.13 or later only.