

Certificate of Compliance

Certificate: 1622082

Master Contract: 228222

Project: 2095131

Date Issued: October 9, 2008

Issued to: Pilz GmbH & Co.
Felix Wankelstrasse 2
Ostfildern, 73760
GERMANY


*The products listed below are eligible to bear the CSA Mark shown
with adjacent indicators 'C' and 'US'*



Issued by:


Carole Lemay

Authorized by:


Hélène Vaillancourt
Operations Manager

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices
CLASS 3211 83 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices -
CERTIFIED TO U.S. STANDARDS

- Limit switches, Type I88 or PSEN, rated A300, A1, A2, E1, E2, U15, UV15, U16 or UV16, rated B300, Enclosure Type 4X, indoor use only.
- Limit switches with magnetic or mechanical locking mechanism, enclosed, Type PSEN, 24 Vac/dc or 24-230 Vac/dc, rated B300, R300, 5A 250 Vac G.P. Ambient temperature 70° C, type 4 indoor use only, Provided with maximum four NO contacts and / or NC contacts or a combination thereof..
- Limit switches, Type PSEN, rated A300, A1, A2, UV15, UV16, U15, U16, E1 or E2, rated B300, Enclosure Type 4X, indoor use only.
- Limit switches, Type PSEN, Enclosure Type 4X, indoor use only, rated 10A, 300V ac G.P., B300.
- Limit switches with magnetic or mechanical locking mechanism, enclosed, Types PSEN me1s/1AS, PSEN me1S/1AR, PSEN me1/1AS, PSEN me1M/1AR, 24 Vac/dc or 24-230 Vac/dc, rated B300, R300, 5A 250 Vac G.P. Ambient temperature 70° C, type 4 indoor use only, Provided with maximum four NO contacts and / or NC contacts or a combination thereof..

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards 162208 December 6, 2002 228221 1622082

Certificate: 1622082

Master Contract: 228222

- Limit switches with a magnetic or mechanical locking mechanism, enclosed, Type PSEN me1 may be followed by 24Vac/dc or 24-230Vac/dc, rated B300, R300, 5A 250V ac G.P. Type 4 indoor use only, provided with maximum four NO contacts and/or NC contacts or a combination thereof.

MARKINGS

Listee's name and/or CSA file number 228222, model designation, complete electrical rating in volts, hertz, hp, amps, serial number or date coding, and the CSA Mark appear in a permanent manner on each unit.

The cCSAus monogram may appear next to the CSA Mark