

产品认证证书

II型自愿认证

证书编号: CQC2016010303925078

发证日期: 2021年12月15日

有效期至: 2031年12月15日

委托人名称及注册地址 皮尔磁工业自动化(上海)有限公司
中国(上海)自由贸易试验区泰谷路169号B座二层210室

制造商名称及注册地址 皮尔磁电子(常州)有限公司
江苏省常州市金坛区云湖路58号

生产企业名称及生产地址 皮尔磁电子(常州)有限公司
江苏省常州市金坛区云湖路58号

产品名称和系列、规格、型号 继电器
PNOZ X; Uimp: 6kV; Ui: 250V; Ith: 8A; Ue: AC230V, DC24V; Ie: AC5A, AC3A, DC7A, DC5A, DC4A; 使用类别: AC-15, DC-13; 外壳防护等级: IP20; 控制电源电压: 24-240VAC/DC; 型号解释详见附件

产品标准和技术要求 GB/T 14048.5-2017

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年09月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人

签发

徐军 谢肇煦

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0125960

产品认证证书

II型自愿认证

证书编号: CQC2016010303925078

第1页 共1页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 125960

型号的解释:

PNOZ X V 3 P HT
(1) (2) (3) (4) (5)

(1) 安全继电器
X: X系列型号

(2) 延时功能类型
空: 无延时
V: 有延时

(3) 代表输出触点类型和输入工作电压
1: 安全触点 3NO, 标准触点 1NC, Cat.2
2: 安全触点 3NO
2.1: 安全触点 3NO, 标准触点 1NC, Cat.4
2.2: 安全触点 3NO, 标准触点 1NC, Cat.4 手动复位
2.3: 安全触点 3NO, 标准触点 1NC, Cat.4 可插拔
2.4: 安全触点 3NO, 标准触点 1NC, 延时触点断开
2.5: 安全触点 3NO, 标准触点 1NC
2.7: 安全触点 2NO
2.8: 安全触点 3NO, 标准触点 2NC, 1SC, 手动复位
2.9: 安全触点 3NO, 标准触点 1NC, 手动复位
3: 安全触点 3NO, 标准触点 1NC, 1SC, 手动复位

3.1: 安全触点 3NO, 标准触点 2NC, 1SC, 交直流通用电源
3.2: 安全触点 3NO, 标准触点 2NC, 1SC, 交流电源
3.3: 安全触点 3NO, 标准触点 3NC
3.10: 安全触点 3NO, 标准触点 1NC, 1SC, 手动复位, 可插拔
4: 安全触点 3NO, 标准触点 1NC
5: 安全触点 2NO, 交直流通用电源
5.1: 安全触点 2NO, 直流电源
6: 安全触点 3NO
7: 安全触点 2NO, SIL2
7.1: 安全触点 1NO, 标准触点 1NC, SIL2
8: 安全触点 3NO, 标准触点 1NC, 2SC
9: 安全触点 7NO, 标准触点 2NC, 2SC
10: 安全触点 6NO, 标准触点 4NC
10.1: 安全触点 6NO, 标准触点 4NC, 1SC
10.11: 安全触点 6NO, 标准触点 4NC, 2SC, 交直流通用电源, 可插拔
11: 安全触点 7NO, 标准触点 1NC, 2SC
13: 安全触点 5NO, 标准触点 1NC

(4) 代表接线端子为插拔类型
空: 螺丝端子连接
P: 插拔式端子
C: 笼式压簧端子

(5) 特定客户代码



中国质量认证中心



CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2016010303925078

Valid from: Dec.15,2021

Valid until: Dec.15,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Pilz Industrial Automation (Shanghai)Co.,Ltd
Room 210, 2f, block B, No. 169, Taigu Road, China (Shanghai) pilot Free Trade Zone

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Pilz Electronics (ChangZhou)Co.,Ltd.
No 58,Yunhu Road,JinTan District, Changzhou City, Jiangsu Province

NAME AND LOCATION OF THE FACTORY Pilz Electronics (ChangZhou)Co.,Ltd.
No 58,Yunhu Road,JinTan Area

PRODUCT NAME, MODEL AND SPECIFICATION Relay
PNOZ X ; Uimp : 6kV ; Ui : 250V ; Ith : 8A ; Ue : AC230V , DC24V ; Ie : AC5A , AC3A , DC7A , DC5A ,DC4A ;Utilization Category :AC-15 ,DC-13 ;Levels of Protection :IP20 ;Uc :24-240VAC/DC ;
See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.26,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

徐军

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

