



产品认证证书

证书编号: CQC2010010303419235

申请人名称及地址

皮尔磁工业自动化(上海)有限公司
中国(上海)自由贸易试验区富特西一路115号2号6层S3部位

制造商名称及地址

皮尔磁工业自动化有限公司
德国奥斯费登, 夫莱克斯-万科街2号, D-73760

生产企业名称及地址

皮尔磁工业自动化有限公司贝斯其多夫工厂(V058381)
法国贝斯其多夫, 路德莫林斯, F-67660

产品名称和系列、规格、型号

安全继电器

PNOZ; Uimp: 4kV; Ui: 250V; Ith: 8A; Ue: AC230V, DC24V; Ie: AC6A, AC5A, AC3A, DC7A, DC6A, DC5A, DC4A; 使用类别: AC-15, DC-13; 外壳防护等级: IP20; 型号解释见附件

产品标准和技术要求

GB/T14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020年10月29日 有效期至: 2025年03月27日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任:

陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0422531



产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC2010010303419235

纸 号: 422531

型号解释:

PNOZ ☐ ☐ ☐
(1) (2) (3) (4)

- (1) 安全继电器基本型号
- (2) 代表触点类型 (X、XV、S、m)
- (3) 代表输出触点数和输入工作电压
- (4) 代表接线端子类型

注: 此附录与证书同时使用时有效。

主任: 陆杨



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2010010303419235

NAME AND ADDRESS OF THE APPLICANT

Pilz Industrial Automation (Shanghai)Co.,Ltd
Position S3,layer 6 , Building 2,No.115,Fute west one Road, Free trade zone, Shanghai, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Pilz GmbH & Co.,KG
Felix-Wankel-Str.2,73760 Ostfildern, Germany

NAME AND ADDRESS OF THE FACTORY

Pilz GmbH & Co.KGFactory Betschdorf (V058381)
Rue des MoulinsF-67660 Betschdorf, France

PRODUCT NAME, MODEL AND SPECIFICATION

Safety Relay

PNOZ; Uimp: 4kV; Ui: 250V; Ith: 8A; Ue: AC230V, DC24V; Ie: AC6A、AC5A、AC3A、DC7A、
DC6A、DC5A、DC4A; Utilization Category: AC-15、DC-13; IP20;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification
rules of CQC11-462142-2019 .

Valid from: Oct.29,2020

Valid until: Mar.27,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: _____

陆梅

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0422531