

**PNOZ** pps1p




Safety relays

This document is a translation of the original document.

All rights to this documentation are reserved by Pilz GmbH & Co. KG. Copies may be made for internal purposes. Suggestions and comments for improving this documentation will be gratefully received.

Source code from third-party manufacturers or open source software has been used for some components. The relevant licence information is available on the Internet on the Pilz homepage.

Pilz®, PIT®, PMI®, PNOZ®, Primo®, PSEN®, PSS®, PVIS®, SafetyBUS p®, SafetyEYE®, SafetyNET p®, the spirit of safety® are registered and protected trademarks of Pilz GmbH & Co. KG in some countries.



Introduction	4
Validity of documentation	4
Using the documentation	4
Definition of symbols	4
Safety	5
Intended use	5
Safety regulations	5
Use of qualified personnel	5
Warranty and liability	6
Disposal	6
Unit features	6
Block diagram	7
Function Description	7
Installation	7
Wiring	9
Describes for a continu	
Preparing for operation	9
Operation	0
Operation Clarks in disease as	9
Status indicators	9
Faults – Interference	10
radits - interierence	10
Dimensions in mm	10
	10
Technical details	10
. common would	10
Order reference	12
5.45. 15.5.3100	
EC declaration of conformity	12
, , , , , , , , , , , , , , , , , , , ,	

### Introduction

#### Validity of documentation

This documentation is valid for the product PNOZ pps1p. It is valid until new documentation is published.

This operating manual explains the function and operation, describes the installation and provides guidelines on how to connect the product.

#### Using the documentation

This document is intended for instruction. Only install and commission the product if you have read and understood this document. The document should be retained for future reference.

## **Definition of symbols**

Information that is particularly important is identified as follows:



#### **DANGER!**

This warning must be heeded! It warns of a hazardous situation that poses an immediate threat of serious injury and death and indicates preventive measures that can be taken.



#### **WARNING!**

This warning must be heeded! It warns of a hazardous situation that could lead to serious injury and death and indicates preventive measures that can be taken.



#### **CAUTION!**

This refers to a hazard that can lead to a less serious or minor injury plus material damage, and also provides information on preventive measures that can be taken.



## **NOTICE**

This describes a situation in which the product or devices could be damaged and also provides information on preventive measures that can be taken. It also highlights areas within the text that are of particular importance.



#### **INFORMATION**

This gives advice on applications and provides information on special features

## Safety

#### Intended use

The power supply unit PNOZ pps1p is intended for use in the modular safety system PNOZpower. It supplies base unit and expansion units with the required internal supply voltage.

The following is deemed improper use in particular:

- Any component, technical or electrical modification to the product
- Use of the product outside the areas described in this manual
- Use of the product outside the technical details (see Technical details [44 10]).



#### **NOTICE**

EMC-compliant electrical installation

The product is designed for use in an industrial environment. The product may cause interference if installed in other environments. If installed in other environments, measures should be taken to comply with the applicable standards and directives for the respective installation site with regard to interference.

#### Safety regulations

#### Use of qualified personnel

The products may only be assembled, installed, programmed, commissioned, operated, maintained and decommissioned by competent persons.

A competent person is someone who, because of their training, experience and current professional activity, has the specialist knowledge required to test, assess and operate the work equipment, devices, systems, plant and machinery in accordance with the general standards and guidelines for safety technology.

It is the company's responsibility only to employ personnel who:

- Are familiar with the basic regulations concerning health and safety / accident prevention
- Have read and understood the information provided in this description under "Safety"
- And have a good knowledge of the generic and specialist standards applicable to the specific application.

## Warranty and liability

All claims to warranty and liability will be rendered invalid if

- The product was used contrary to the purpose for which it is intended
- Damage can be attributed to not having followed the guidelines in the manual
- Operating personnel are not suitably qualified
- Any type of modification has been made (e.g. exchanging components on the PCB boards, soldering work etc.).


## **Disposal**

When decommissioning, please comply with local regulations regarding the disposal of electronic devices (e.g. Electrical and Electronic Equipment Act).

#### **Unit features**

- Connection options for:
  - 1 base unit
  - Maximum 4 expansion modules
- LED indicator for:
  - Supply voltage
  - Output voltage
- Galvanic isolation
- Short circuit-proof

# **Block diagram**



# **Function Description**

The power supply unit PNOZ pps1p supplies the base unit and the expansion modules of the modular safety system PNOZpower with the required supply voltage. When operating voltage is supplied the "POWER IN" LED will light. The "POWER OUT" LED will light when the output voltage is correct. Depending on the plant state it is 19 V DC or 24 V DC. The output voltage is fed to the terminals 0 V and +24 V for measuring purposes.

#### Installation


- The unit should be installed in a control cabinet with a protection type of at least IP54.
- Use the notches on the rear of the unit to attach it to a DIN rail.
- Fit the unit to a horizontal DIN rail. If other mounting positions are used, the switching capability values stated in the technical details cannot be maintained.
- There are 2 sockets on the rear of the PNOZ pps1p.
  The base unit/control module and the expansion modules are connected using the jumpers supplied.



## NOTICE

Always connect a terminator to the first and last device.

- Only use terminators, jumpers and terminals of the modular safety system PNOZpower.
- Layout:
  - The power supply unit PNOZ pps1p can be installed in any position on the PNOZpower modular safety system.
- Maximum hardware:
  - 1 base unit
  - 4 expansion modules
  - 1 power supply unit





## **WARNING!**

Risk of electrocution!

When voltage is applied, contact with live components could result in serious or even fatal injury from an electric shock.

The plug-in connection terminals should only be connected and disconnected when the voltage is switched off.


PNOZ pps1p

# Wiring

#### Please note:

- Information given in the "Technical details [ 10] must be followed.
- The output voltage can be measured at the terminals 0 V and +24 V.
- Do not connect external user to the terminals 0 V and +24 V!
- When the PNOZ pps1p power supply unit is used, the base unit draws power via the PNOZpower bus. Do not connect an external supply voltage to terminals A1 and A2 of the base unit!
- ▶ Use copper wire that can withstand 60/75 °C.
- Ensure the wiring and EMC requirements of IEC 60204-1 are met.

## **Preparing for operation**



# Operation



## **NOTICE**

The safety function should be checked after initial commissioning and each time the plant/machine is changed. The safety functions may only be checked by qualified personnel.

#### Status indicators

LEDs indicate the status and errors during operation:



LED on



#### **POWER IN**

Supply voltage is present.




#### **POWER OUT**

Output voltage 19 V DC or 24 V DC is present at PNOZpower bus

# Faults - Interference

- LED "POWER IN" does not light: Supply voltage is missing.
- ▶ LED "POWER OUT" does not light: Short circuit or supply voltage failure.

# Dimensions in mm



# **Technical details**

General	
Approvals	CCC, CE, EAC (Eurasian), TÜV, cULus Listed
Electrical data	
Supply voltage	
Voltage	100 - 240 V
Kind	AC
Voltage tolerance	-15 %/+10 %
Output of external power supply (AC)	30 VA
Frequency range AC	50 - 60 Hz
Duty cycle	100 %
Output voltage	
Voltage	19 V, 24 V
Kind	DC
Output power	15 W
Times	
Supply interruption before de-energisation	20 ms
Environmental data	
Climatic suitability	EN 60068-2-78
Ambient temperature	
Temperature range	-10 - 55 °C
Storage temperature	
Temperature range	-40 - 85 °C

Environmental data		
Climatic suitability		
Humidity	93 % r. h. at 40 °C	
Condensation during operation	Not permitted	
EMC	EN 60947-5-1, EN 61000-6-2, EN 61000-6-3	
Vibration		
In accordance with the standard	EN 60068-2-6	
Frequency	10 - 55 Hz	
Amplitude	0,35 mm	
Airgap creepage		
In accordance with the standard	EN 60947-1	
Overvoltage category	III	
Pollution degree	2	
Rated insulation voltage	250 V	
Rated impulse withstand voltage	4 kV	
Protection type		
Mounting area (e.g. control cabinet)	IP54	
Housing	IP40	
Terminals	IP20	
Mechanical data		
Mounting position	Horizontal on top hat rail	
Material		
Bottom	PPO UL 94 V0	
Front	ABS UL 94 V0	
Тор	ABS UL 94 V0	
Connection type	Screw terminal	
Mounting type	plug-in	
Conductor cross section with screw terminals		
1 core flexible	0,2 - 2,5 mm², 24 - 14 AWG	
2 core with the same cross section, flexible with		
crimp connectors, no plastic sleeve	0,25 - 1 mm², 24 - 14 AWG	
2 core with the same cross section, flexible without crimp connectors or with TWIN crimp connectors	0,5 - 1,5 mm²,	
Torque setting with screw terminals	0,5 Nm	
Dimensions		
Height	94 mm	
Width	45 mm	
Depth	121 mm	
Weight	285 g	

Where standards are undated, the 2014-07 latest editions shall apply.

# Order reference

Product type	Features	Connection type	Order No.
PNOZ pps1p	Supply voltage: 100-240 V AC	Screw terminals	773 200
	Output voltage: 19 V DC; 24 V DC		

# EC declaration of conformity

This product/these products meet the requirements of the directive 2006/42/EC for machinery of the European Parliament and of the Council. The complete EC Declaration of Conformity is available on the Internet at www.pilz.com/support/downloads. Representative: Norbert Fröhlich, Pilz GmbH & Co. KG, Felix-Wankel-Str. 2, 73760 Ostfildern, Germany

SafetyEYE®, SafetyNET p® THE SPIRIT OF SAFETY® are registered and protected trademarks of PliZ GmbH & Co. KG in some countries. We would point out that product features mit from the details stated in this document, depending on the status at the time of publication and the scope of the equipment. We accept no responsibility for the validity, accuracy and entirety of the text and graphics presented in this information. Please contact our Technical Support if you have any questions.

InduraNET p®, PAS4000®, PAScal®, PASconfig®, Pilz®,

PIT®, PUD®, PMCprimo®, PMCprotego®, PMCtendo®, PMD®, PMI®, PNOZ®, Primo®, PSEN®, PSS®, PVIS®, SafetyBUS

Technical support is available from Pilz round the clock.

Americas
Brazil
FF 44 07F00 (

+55 11 97569-2804

Canada

+1 888-315-PILZ (315-7459)

Mexico

+52 55 5572 1300 USA (toll-free)

+1 877-PILZUSA (745-9872)

## Asia

China

+86 21 60880878-216

Japan

+81 45 471-2281

South Korea +82 31 450 0680

### Australia

+61 3 95446300

#### Europe

Austria

+43 1 7986263-0

Belgium, Luxembourg

+32 9 3217575

France

+33 3 88104000

Germany

+49 711 3409-444

Ireland

+353 21 4804983

Italy

+39 0362 1826711

Scandinavia

+45 74436332

Spain

+34 938497433

Switzerland

+41 62 88979-30

The Netherlands

+31 347 320477

Turkey

+90 216 5775552

United Kingdom

+44 1536 462203

# You can reach our international hotline on:


+49 711 3409-444 support@pilz.com

Pilz develops environmentally-friendly products using ecological materials and energy-saving technologies.

Offices and production facilities are ecologically designed, environmentally-aware and energy-saving. So Pilz offers sustainability, plus the security of using energy-efficient products and environmentally-friendly solutions.













Pilz GmbH & Co. KG
Felix-Wankel-Straße 2
73760 Ostfildern, Germany
Tel.: +49 711 3409-0
Fax: +49 711 3409-133
info@pilz.com
www.pilz.com

