

# 产品认证证书

## II型自愿认证

证书编号: CQC2003010303066461

发证日期: 2021年01月12日

有效期至: 2031年01月12日

委托人名称 及注册地址	皮尔磁工业自动化(上海)有限公司 中国(上海)自由贸易试验区富特西一路115号2号6层S3部位
制造商名称 及注册地址	皮尔磁工业自动化有限公司 德国奥斯费登,夫莱克斯-万科街2号,D-73760
生产企业名称 及生产地址	皮尔磁工业自动化有限公司 德国奥斯费登,夫莱克斯-万科街2号,D-73760
产品名称和系列、 规格、型号	继电器 PZE(型号解释详见附件); Uimp: 4kV; Ui: 250V; Ith: 10A; Ue: AC230V, DC24V; Ie: AC5A, AC3A, DC7A, DC5A, DC4A; 使用类别: AC-15, DC-13; 外壳防护等级: IP20
产品标准和技术要求	GB/T 14048.5-2017
认证模式	型式试验+初始工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人:

陈昕

主任:

陆楠

# 中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0002998



# 产品认证证书

## II型自愿认证

附 录

证书编号: CQC2003010303066461

第 1 页 共 1 页

纸 号: 2998

· 型号的解释(Explanation of model/ type):

<u>PZE</u>	<u>X4</u>	<u>PC</u>
(1)	(2)	(3)

- (1) 安全继电器的基本型号
- (2) 代表输出触点类型和输入工作电压
- (3) 代表接线端子类型 (P-接线端子可插拔, PC-笼式压簧接线端子可插拔)

注: 此附录与证书同时使用时有效。

# 附件



## 中国质量认证中心



# PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2003010303066461

Valid from: Jan.12,2021

Valid until: Jan.12,2031

**NAME AND REGISTERED ADDRESS OF THE APPLICANT** Pilz Industrial Automation (Shanghai)Co.,Ltd  
Position S3,layer 6 , Building 2,No.115,Fute west one Road, Free trade zone, Shanghai, P.R.China

**NAME AND REGISTERED ADDRESS OF THE MANUFACTURER** Pilz GmbH & Co.,KG  
Felix-Wankel-Str.2,73760 Ostfildern, Germany

**NAME AND LOCATION OF THE FACTORY** Pilz GmbH & Co.,KG  
Felix-Wankel-Strasse, D-73760 Ostfildern

**PRODUCT NAME, MODEL AND SPECIFICATION** Relay  
PZE; Uimp : 4kV ; Ui : 250V ; Ith : 10A ; Ue : AC230V , DC24V ; Ie : AC5A, AC3A, DC7A, DC5A, DC4A ; AC-15, DC-13 ; IP20

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS** GB/T 14048.5-2017

**TYPE OF CERTIFICATION SCHEMES** Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.  
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNED BY:

PRESIDENT:

CHINA QUALITY CERTIFICATION CENTRE

