

产品认证证书

II型自愿认证

证书编号: CQC2011010303516377

发证日期: 2021年11月26日

有效期至: 2031年11月26日

委托人名称 皮尔磁工业自动化(上海)有限公司
及注册地址 中国(上海)自由贸易试验区泰谷路169号B座二层210室

制造商名称 皮尔磁工业自动化有限公司贝斯其多夫工厂
及注册地址 法国贝斯其多夫,路德莫林斯,F-67660

生产企业名称 皮尔磁工业自动化有限公司贝斯其多夫工厂
及生产地址 法国贝斯其多夫,路德莫林斯,F-67660

产品名称和系列、规格、型号 安全继电器
PZE;型号解释详见附件; Uimp: 4kV; Ui: 250V; Ith: 10A; Ue: AC230V, DC24V; Ie: AC5A, AC3A, DC7A, DC5A, DC4A; 使用类别: AC-15, DC-13; 外壳防护等级: IP20

产品标准和技术要求 GB/T 14048.5-2017

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年10月29日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人

陈昕

签发

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0118279

产品认证证书

II型自愿认证

附 录

证书编号: CQC2011010303516377

第 1 页 共 1 页

纸 号: 118279

型号的解释(Explanation of model/ type):

<u>PZE</u>	<u>X4</u>	<u>PC</u>
(1)	(2)	(3)

- (1) 安全继电器的基本型号
- (2) 代表输出触点类型和输入工作电压
- (3) 代表接线端子类型 (P-接线端子可插拔, PC-笼式压簧接线端子可插拔)

注: 此附录与证书同时使用时有效。



中国质量认证中心



CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2011010303516377

Valid from: Nov.26,2021

Valid until: Nov.26,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Pilz Industrial Automation (Shanghai)Co.,Ltd
Room 210, 2f, block B, No. 169, Taigu Road, China (Shanghai) pilot Free Trade Zone

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Pilz GmbH & Co.KGFactory Betschdorf
Rue des MoulinsF-67660 Betschdorf, France

NAME AND LOCATION OF THE FACTORY Pilz GmbH & Co.KGFactory Betschdorf
Rue des MoulinsF-67660 Betschdorf, France

PRODUCT NAME, MODEL AND SPECIFICATION Safety Relay
PZE;Uimp : 4kV ; Ui : 250V ; Ith : 10A ; Ue : AC230V , DC24V ; Ie : AC5A, AC3A, DC7A, DC5A, DC4A ; AC-15, DC-13 ; IP20

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Oct.29,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0118279